

TERMOKIMIK FOR SERVICES COMPANY IN PADOVA

Shop number: 4640 – Construction year: 2008

MAIN TECHNICAL DATA:

Boiler	
Circulation	Natural
Steam flow	51 t/h
Operating pressure	45 barg
Inlet water temperature	140 °C
Outlet steam temperature	400 °C
Outlet gas temperature	195 °C
Recovered heat	37 MW
Clearing system	Hammer

Heat Source	
Grate	Martin
Gas flow	30 kg/s
Gas temperature	1140 °C
Dust content	400 kg/h
Heat supplied	43 MW

