

ANSALDO FOR MAZZUCHELLI COMPANY IN CASTIGLIONE OLONA

Shop number: 3935 – Erection year: 1992

MAIN TECHNICAL DATA:

Boiler	Recovery	Post-firing	Fresh Air	
Steam flow	8	20	15	t/h
Operating pressure	48	48	48	barg
Inlet water temperature	105	105	105	°C
Outlet steam temperature	405	420	420	°C
Gas flow	17	17	5	Kg/s
Inlet gas temperature	520	920	1500	°C
Outlet gas temperature	190	120	100	°C
Recovered heat	6	16	12	MW

Heat Source		
Gas turbine		Solar Centaur
Gas flow		17 kg/s
Gas temperature		520 °C

