

AERIMPIANTI FOR MUNICIPALIZED ELECTRIC COMPANY IN LE VALLETTE

Shop number: 3880 – Erection year: 1992

MAIN TECHNICAL DATA:

<u>Boiler</u>		
Superheater steam flow	30	t/h
Operating pressure	37	barg
Outlet steam temperature	400	°C
Outlet gas temperature	160	°C
Recovered heat	23	MW

Heat SourceDiesel motor26 kg/sGas flow26 kg/sGas temperature1100 °C



